MXT-38812241

STAINLESS STEEL SIGHT GLASS WITH DOME AND ROTOR

FEATURES

The MXT sight glass with dome and rotor is designed for the visual inspection of flow for fluids inside piping. Made of stainless steel with a PP rotor and a glass dome, it is especially designed for process fluids.

The dome type provides particularly easy visibility. Horizontal mounting on installations. Unidirectional operation.



MXT-2: G 1/4" to G 1" G thread connections



LIMITS OF USE

| Fluid WP: | 16 bar |
|------------|--------------|
| Fluid WT°: | -5°C / +80°C |





DIRECTIVES AND MANUFACTURING STANDARDS

| ОВЈЕСТ | Standard | |
|---------------------------------------|----------------------|--|
| Pressure Equipment Directive 97/23/EC | A3 § 3 non-submitted | |
| Stainless steel grade | EN 10213-4 | |
| Threaded connection | BSPP-ISO 228 | |

FLOW-RATE TABLE

| DN | Minimum flow-rate (I/minute) | Maximum flow-rate (I/minute) | ΔP (v = 2 m/s) bar |
|--------|------------------------------|------------------------------|-----------------------|
| G 1/4" | 0.8 | 31 | 0.15 |
| G 3/8" | 0.9 | 41 | 0.18 |
| G 1/2" | 1.1 | 56 | 0.21 |
| G 3/4" | 1.4 | 95 | 0.2 |
| G 1" | 2.0 | 145 | 0.5 |




MXT-38812241

MXT-2 STAINLESS STEEL SIGHT GLASS WITH DOME AND ROTOR


DIMENSIONS (mm) AND WEIGHT (kg))


| DN | A | В | С | Weight (kg) |
|--------|----|----|----|----------------|
| G 1/4" | 76 | 63 | 65 | 0.5 |
| G 3/8" | 76 | 63 | 65 | 0.7 |
| G 1/2" | 76 | 63 | 65 | 1.1 |
| G 3/4" | 89 | 63 | 83 | 1.2 |
| G 1" | 89 | 63 | 83 | 1.4 |



CONSTRUCTION

| No. | Name | Material |
|-----|-------------|----------------------|
| 1 | Body | 1.4408 SS |
| 2 | Cover | 1.4408 SS |
| 3 | Dome | Toughened glass |
| 4 | Gasket | FPM |
| 5 | Rotor guide | 1.4408 SS |
| 6 | Rotor | PP + 10% glass fibre |
| 7 | Bolt | Stainless steel |





ASSEMBLY AND SERVICING

Cut-off the piping upstream and downstream, depressurize, bleed and wait for it to cool down at ambient temperature before installation.

Loosen bolts, remove the cover, clean the glass dome and the internal parts.

Reassemble the parts in the reverse order.

Put the installation back in operation.